



ODISHA HYDRO POWER CORPORATION LTD.,

O/o Sr. GENERAL MANAGER, HIRAKUD HYDRO ELECTRIC PROJECT,
POST BOX. NO. 5, BURLA – 768017, DISTRICT: SAMBALPUR (ODISHA), INDIA
PHONE: 0663-2950721(O), 2950765(R), E-Mail: srgmhps_burla@yahoo.co.in
GST NO. 21AAACO2575P1Z9, CIN : U40101OR1995SGC003963

TENDER CALL NOTICE NO. HHEP- 33 /2026

Tender Specification for

“Supply and Retrofit of 02 Nos of 800Amp ACB and 02 Nos of 1250Apm ACB for replacement against Merlin Gerin make ACB of SSB-I, incomer-I & II and Incomer-II of UAB-I & II of Burla Power House”.

Name of the Firm:

Corresponding Address with Contact Telephone No.

Cost of tender paper :

**Rs. 7080/- (Rs 6000.00 + GST @18% Rs 1080.00)
(Rupees Seven thousand & eighty) only**



ODISHA HYDRO POWER CORPORATION LTD.,

O/o Sr. GENERAL MANAGER, HIRAKUD HYDRO ELECTRIC PROJECT,
POST BOX. NO. 5, BURLA – 768017, DISTRICT: SAMBALPUR (ODISHA), INDIA
PHONE: 0663-2950721(O), 2950765(R), E-Mail: srgmhps_burla@yahoo.co.in
GST NO. 21AAACO2575P1Z9, CIN : U40101OR1995SGC003963

CONTENTS

PART-1:

TECHNO – COMMERCIAL BID

1. Section-I : Instruction to Tenderer
2. Section-II : General Terms & Conditions
3. Section-III : Special Terms & Conditions
4. Section-IV Annexures

PART-II:

PRICE BID



ODISHA HYDRO POWER CORPORATION LTD.,

O/o Sr. GENERAL MANAGER, HIRAKUD HYDRO ELECTRIC PROJECT,
POST BOX. NO. 5, BURLA – 768017, DISTRICT: SAMBALPUR (ODISHA), INDIA
PHONE: 0663-2950721(O), 2950765(R), E-Mail: srgmhps_burla@yahoo.co.in
GST NO. 21AAACO2575P1Z9, CIN : U40101OR1995SGC003963

(TECHNO – COMMERCIAL BID)

**“Supply and Retrofit of 02 Nos of 800Amp ACB and 02
Nos of 1250Apm ACB for replacement against Merlin
Gerin make ACB of SSB-I, incomer-I & II and Incomer-II
of UAB-I & II of Burla Power House”**

TENDER CALL NOTICE NO: HHEP- 33 /2026



ODISHA HYDRO POWER CORPORATION LTD.,

O/o Sr. GENERAL MANAGER, HIRAKUD HYDRO ELECTRIC PROJECT,
POST BOX. NO. 5, BURLA – 768017, DISTRICT: SAMBALPUR (ODISHA), INDIA
PHONE: 0663-2950721(O), 2950765(R), E-Mail: srgmhps_burla@yahoo.co.in
GST NO. 21AAACO2575P1Z9, CIN : U40101OR1995SGC003963

SECTION-I

INSTRUCTION TO TENDERER

- 1.1 **SCOPE & TECHNICAL WORK:** The scope & technical work is as per Section IV. It is the bidders responsibility to ascertain the detail scope of works and technical specification as per requirement of tender **after due physical inspection at site during any working days in coordination with Divisional Head, P&C Division, Burla (Cell No. 7328840368) before quoting for the bid.**
- 1.2 **CORRESPONDENCE :** All correspondences shall be made in English only to the Unit Head, HHEP, Burla
- 1.3 **SCHEDULE OF DATES:** The various crucial dates relating to the tender for “Supply and Retrofit of 02 Nos of 800Amp ACB and 02 Nos of 1250Apm ACB for replacement against Merlin Gerin make ACB of SSB-I, incomer-I & II and Incomer-II of UAB-I & II of Burla Power House” are cited as under:
- | | | |
|---|---|---|
| a) Period of sale / download of tender document | : | 10:00AM of dtd. 22.04.2026 to 06.05.2026 upto 01:00PM |
| b) Last date & Time of receipt of tender document | : | 07.05.2026 upto 11:00AM |
| c) Date & Time of opening of Techno Commercial bid | : | 07.05.2026 at 11:30AM |
| d) Date and time for opening of financial / price bid | : | The date and time of technically qualified bidders will be intimated separately |
- If the last date of receipt of tender document and date of opening of tender document falls on a holiday, the next working day and time will be the corresponding effective date.
- 1.4 **COST OF TENDER PAPER:** The tender specification should be accompanied with the cost of tender paper of Rs. 7080/- (Rs. 6000/- + GST 18%) in shape of Bank draft/ Bankers Cheque from any Nationalised Bank /Scheduled bank drawn in favour of “OHPC Ltd., HHEP, Burla” payable at Burla.
- 1.5 **EMD:** The tenderers are required to deposit an amount of Rs. 20,300/- (Refundable) as EMD in shape of Bank Draft/ Bankers Cheque from any nationalized bank/ scheduled bank drawn in favour of “HHEP, Burla, OHPC Ltd.,” payable at Burla along with tender documents, failing which the offer will be out rightly rejected and no further correspondence in this regard will be entertained.
- The EMD amount will not carry any interest
 - The EMD of unsuccessful bidder will be returned after finalization of tender
 - The EMD of successful bidder will be returned after submission of Security Deposit/ Performance Bank Guarantee as per tender specification

1.6 **ELIGIBILITY CRITERIA:** The firm should be Manufacturer or its Authorized dealer only having valid Firm Registration Certificate issued by Govt. Authority / Dealership certificate and executed at least two such similar types of Works/Orders in the last three years. Documentary evidence in support of eligibility criteria shall be submitted.

1.7 **DOCUMENTS TO BE SUBMITTED ALONG WITH THE BID:-**

a) The following Documents to be submitted along with Technical Bid in part-I in one sealed envelope to be super scribed as "Technical Bid" .

The technical bid shall be contained with the following documents:

- i) Cost of Tender paper as per above at sl no-1.4
 - ii) EMD as above at sl no-1.5
 - iii) Self-attested Copies of IT PAN & GSTIN
 - iv) Self attested copy of Manufacturer's Registration Certificate issued by Govt. Authority (For Manufacturer only)
 - v) Self attested copy of valid dealership certificate along with Manufacturers authorization certificate for participating in the tender (For Authorized dealer only).
 - vi) **An original affidavit by the tenderer, that the firm is not black listed. (as per prescribed format as per annexure-5)**
 - vii) **Successful work completion certificate / performance certificate from any Govt organization/ PSUs towards work experience**
 - viii) **Manufacturers Drawings & Literatures of the offered Equipments**
 - ix) **Type test reports of the offered Air Circuit Breaker as per relevant IS**
 - x) Down load Copy of the tender document/ Tender paper to be signed on each page .
 - xii) No relation certificate as per Annexure-2, Experience certificate as per Annexure-3, Check list as per Annexure-4, Declaration form as per Annexure-6, Deviation from specification as per Annexure-7, **Guaranteed Technical Particular as per Annexure-8** should be submitted along with the technical bid
- b) Price bid in the prescribed form given in Part –II in another sealed cover super scribed as "Price bid"
- c) Both the covers i.e Technical Bid and Price bid should be placed inside another sealed cover super scribed with **TCN No. HHEP- 33 /2026** & marked as "Supply and Retrofit of 02 Nos of 800Amp ACB and 02 Nos of 1250Apm ACB for replacement against Merlin Gerin make ACB of SSB-I, incomer-I & II and Incomer-II of UAB-I & II of Burla Power House"

15/17
15.04.26
C&P Head, HHEP, Burla



ODISHA HYDRO POWER CORPORATION LTD.,

O/o Sr. GENERAL MANAGER, HIRAKUD HYDRO ELECTRIC PROJECT,
POST BOX. NO. 5, BURLA – 768017, DISTRICT: SAMBALPUR (ODISHA), INDIA
PHONE: 0663-2950721(O), 2950765(R), E-Mail: srgmhps_burla@yahoo.co.in
GST NO. 21AAACO2575P1Z9, CIN : U40101OR1995SGC003963

SECTION –II GENERAL TERMS AND CONDITIONS

2.1 PREPARATION OF BID:

- a) The following Documents to be submitted along with Technical Bid in part-I in one sealed envelope to be super scribed as “Technical Bid”.

The technical bid shall be contained with the following documents:

- i) Cost of Tender paper as per above at sl no-1.4
 - ii) EMD as above at sl no-1.5
 - iii) Self-attested Copies of IT PAN & GSTIN
 - iv) Self attested copy of Manufacturer’s Registration Certificate issued by Govt. Authority (For Manufacturer only)
 - v) Self attested copy of valid dealership certificate along with Manufacturers authorization certificate for participating in the tender (For Authorized dealer only).
 - vi) **An original affidavit by the tenderer, that the firm is not black listed. (as per prescribed format as per annexure-5)**
 - vii) **Successful work completion certificate / performance certificate from any Govt organization/ PSUs towards work experience**
 - viii) **Manufacturers Drawings & Literatures of the offered Equipments**
 - ix) **Type test reports of the offered Air Circuit Breaker as per relevant IS**
 - x) Down load Copy of the tender document/ Tender paper to be signed on each page .
 - xi) No relation certificate as per Annexure-2, Experience certificate as per Annexure-3, Check list as per Annexure-4, Declaration form as per Annexure-6, Deviation from specification as per Annexure-7, **Guaranteed Technical Particular as per Annexure-8** should be submitted along with the technical bid
- b) Price bid in the prescribed form given in Part –II in another sealed cover super scribed as “Price bid”
- c) Both the covers i.e Technical Bid and Price bid should be placed inside another sealed cover super scribed with **TCN No. HHEP- 33 /2026** & marked as “Supply and Retrofit of 02 Nos of 800Amp ACB and 02 Nos of 1250Apm ACB for replacement against Merlin Gerin make ACB of SSB-I, incomer-I & II and Incomer-II of UAB-I & II of Burla Power House”

2.2 CLARIFICATION & AMENDMENT

- i) At any time before submission of bid, the client may, for any reason, modify the tender documents by amendment. **The amendment, if any, shall be issued through an addendum which shall be kept on the official website of OHPC for information of the firms / agencies who intend to submit quotation.** Before submitting the bid the firms / agencies are advised to go through the website to find out such addendum

/ errata / corrigendum if any issued by the client. The addendum / errata / corrigendum will be binding on the all firms / agencies submitting the quotation. The client also reserves the right without any obligation or liability to accept or reject any or all the quotation at any stage of the process, to cancel or modify the process or any part thereof or to vary terms and conditions at any time without assigning any reason thereof.

- ii) Tenderers shall carefully examine the tender documents and the technical specification. Should a tender find any discrepancies or omissions from the specification or other documents, he should at once intimate the authority and obtain clarification in writing. This, however, does not entitle the tenderer to ask time beyond the due date fixed for receipt of tenderers.
- iii) In case any bidder who has submitted the bid before issue of corrigendum / addendum etc., if desired can submit a bid superscribing as "revised bid against TCN No. HHEP- 33 /2026" on the envelope containing the tender documents.

2.3 **CORRIGENDUM:** Modification of specifications and extension of closing date or opening date of Tender, if required, will be made by corrigendum. Copies of such corrigendum will be floated in OHPC website only. This shall be signed and shall form a part of the Tender. Tenderers are required to visit the website for such corrigendum / errata / addendum if any.

2.4 **SUBMISSION OF BIDS:-** The tender has been invited under **two part bidding system i.e. Techno commercial Bid and Price Bid**. The interested agencies are advised to submit two separate sealed envelopes for each bid i.e. Techno commercial and price bid super scribing "Tender for Supply and retrofit of ACBs at Burla Power House" on the Techno commercial Bid and super scribing "Price Bid of Tender for Supply and retrofit of ACBs at Burla Power House" on the price bid. Both sealed envelopes should be kept in a third sealed envelope super scribing "**TCN NO-HHEP- 33/2026 for Tender for "Supply and Retrofit of 02 Nos of 800Amp ACB and 02 Nos of 1250Apm ACB for replacement against Merlin Gerin make ACB of SSB-I, incomer-I & II and Incomer-II of UAB-I & II of Burla Power House"** . Bidders shall quote their price as per the price bid format given in PART –II

2.5 **OPENING OF TECHNO-COMMERCIAL BID & PRICE BID:-** The Techno-Commercial bid shall be opened on the scheduled date and time at **11:30AM, 07.05.2026. at** O/o the Sr. GM, OHPC Ltd., HHEP, Burla, Sambalpur in the presence of the tenderer or authorized representative of the tenderer if any who wish to be present on that spot at that time. The price bid of only those tenderers will be opened whose techno – commercial bids are found in order. The date and time of opening of the price bids of technically qualified firms will be intimated later and separately.

2.6 **EVALUATION:-**

- i) Evaluation shall be based on techno – commercial and price bids submitted by the bidders.
- ii) Bidders fulfilling the eligibility criteria as per the above evaluation shall be called for opening of the price bids.
- iii) Bidders not meeting the eligibility criteria shall be excluded for further evaluation.

- iv) The competent authority reserves the right to cancel any or all bids without assigning any reason thereof.

2.7 OUTRIGHT REJECTION CRITERIA:-

- i) Bidders whose bid is not received in time.
- ii) Bidders submitting false evidences that cannot be verified during the process shall be disqualified/ terminated on detection.
- iii) The Bidder blacklisted by any Central Government/ State Government/ PSU/ Government Bodies.
- iv) Bidder not submitting the bid in line with the Tender requirement.
- v) Conditional bids shall not be considered and will be out rightly rejected in very first instance.
- vi) Non-submission of Tender Paper cost, EMD, Valid PAN, Valid GST, Affidavit from Notary, documents in support of proof of eligibility criteria
- vii) If price bid is not found in separate sealed envelope or found in open condition or found along with Techno-Commercial offer.

2.8 COST OF TENDER PAPER: The tender specification should be accompanied with the cost of tender paper for Rs. 7080/- (Rs. 6000/- + GST 18%) in shape of Bank draft/ Bankers Cheque from any Nationalised Bank /Scheduled bank drawn in favour of “OHPC Ltd., HHEP, Burla” payable at Burla along with the tender documents for the tenderers those who will download the tender specification from OHPC website or original money receipt of OHPC for the tenderers those who purchase the tender specification from the O/o the Sr. GM, OHPC Ltd., HHEP, Burla, Sambalpur / OHPC corporate Office , Bhubaneswar.

2.9 EMD:- The tenderers are required to deposit an amount of Rs. 20300/- (Refundable) as EMD in shape of Bank Draft/ Bankers Cheque from any nationalized bank/ scheduled bank drawn in favour of “HHEP, Burla, OHPC Ltd.,” payable at Burla along with tender documents, failing which the offer will be out rightly rejected and no further correspondence in this regard will be entertained.

- i) The EMD amount will not carry any interest
- ii) The EMD of unsuccessful bidder will be returned after finalization of tender
- iii) The EMD of successful bidder will be returned after submission of Security Deposit/ Performance Bank Guarantee as per tender specification

2.10 SCOPE & TECHNICAL SPECIFICATION: The scope of work covers and Technical Specification is as per section-IV.

2.11 PRICE: - The quoted price shall be FIRM & FOR destination-Main Store, HHEP, Burla. The price shall include cost of materials, packing and forwarding, freight & insurance along with retrofitting, Testing & Commissioning Charges and GST as applicable. The tenderers shall have to furnish the GST Rate and Amount with HSN Code in their offer clearly as mentioned in Price Bid Format. No price variation in any shape will be allowed. OHPC will not be held responsible for rise in the cost of labour / raw material / transportation and any such circumstances. The tenderers are advised to quote single price for the item as mentioned in the Price Bid format both in figures and in words. The materials are to be supplied in full and good conditions to the consignee.

- i) The tenderers are advised to quote in the prescribed Price Bid format only. No other mode will be entertained. However, if there is any deviation in the specification and quantity of the quoted item, the bidder should clearly mention in the Annexure-7 (Deviation for Technical or Commercial specification) of the Technical bid with justification.. However, decision of OHPC will be final and binding for its consideration / rejection.
- ii) The tenderer are requested to quote separately the detail of taxes applicable with % on Basic Price and Rates in Rupees

2.12 TAXES & DUTIES:-

- i) Only GST shall be paid as per prevailing rate at the time of invoicing
- ii) Taxes deductible at source shall be deducted from the bills of the firms as per prevailing rules

2.13 BILLS:- The bills in triplicate along with following documents shall be submitted to the Consignee after successful completion of the work for processing for Payment

- i) Warranty certificate in Original
- ii) Manufacturers O&M manual
- iii) Jointly signed Completion Certificate

2.14 VALIDITY:-The bids should have a validity period of 120 days from the date of opening of tenders, failing which the tenders will be rejected

2.15 COMPLETION PERIOD : The work should be completed in all respect within 120 days from the date of issue of work order. The work completion certificate as certified by the Engineer in charge shall be treated as the final completion date. **Early completion of above work is highly preferable and is the essence of the work**

2.16 SECURITY DEPOSIT-CUM-PERFORMANCE BANK GUARANTEE: Successful bidder shall required to furnish a Security Deposit-cum-Performance Bank Guarantee @ 10% of ordered value from any Nationalized / Scheduled Bank, executed in a non-judicial stamp paper of Rs. 100/- (Rupees Hundred) only strictly as per **PROFORMA ENCLOSED / or in shape of Demand Draft** from any Nationalized bank / Schedule bank in favour of **"OHPC Ltd., HHEP, Burla"** payable at **Burla** may be submitted towards security, payment and performance guarantee purpose. The bank guarantee shall be furnished within 15 (fifteen) days from the date of issue of the order and shall remain valid till completion of the warrantee period. The confirmation letter of the concerned bank should be sent alongwith the bank guarantee. In the event of any breach or default in all or any of the conditions set-forth and provided in the work order, OHPC may forfeit the whole amount of the Bank Guarantee. No interest is payable on the Bank Guarantee. In case of non fulfillment of the contract conditions, the security deposit will be forfeited without assigning any reason thereof. No interest shall be paid on the security deposit

2.17 STANDARDS : The materials shall confirm to the latest relevant IS/IEC/CBIP Technical report

- 2.18 **TRANSIT INSURANCE:** Transit insurance of materials should be arranged by the supplier at their own cost. The responsibility of delivery of the materials at destination in full and good condition rests with the supplier. Any claim with the insurance company or transport agency arising due to loss or damage in transit has to be settled by the supplier. The supplier shall undertake for replacement of materials immediately on receipt of such information from Consignee regarding damage or loss, without waiting for settlement for their claims with their carriers and underwriters
- 2.19 **OHPC AUTHORITY RESERVES THE RIGHTS**
- i) To reject any or to accept any or all tenders
 - ii) To increase or decrease the quantity of materials without assigning any reason thereof
 - iii) To split the order.
 - iv) The purchase order will be liable for cancellation in the event of un-satisfactory supply/ delay in supply of materials, and non-observance of relevant clauses of the purchase order
- 2.20 **CONSIGNEE:** Divisional Head, Generation Division, HHEP, Burla
- 2.21 **WARRANTY:-** The materials covered by this specification should be warranted for satisfactory & trouble free operation and against defects in design, materials and workmanship for a period of 18 months from the date of supply or 12 months from the date of commissioning whichever is earlier. Any defect noticed during this period should be rectified by the supplier free of cost to the purchaser provided such defects are due to faulty design, bad workmanship or bad materials used, within one month upon written notice from the purchaser. Such rectification / replacement of materials should also bear the similar warrantee upto the expiry of the original guarantee period
- 2.22 **JURISDICTION:-**All disputes shall be under the jurisdiction of the Hon'ble High Court of Odisha
- 2.23 **AWARD OF WORK:-**The work order will be awarded on the basis of L-1 rate
- 2.24 **SETTLEMENT OF DISPUTE:-**
- i) **Amicable Settlement:-**Any dispute(s) or difference(s) arising out of or in connection with the contract shall to the extent possible , be settled amicably between the parties
 - ii) **Dispute Resolution:-**Decision of competent authority of OHPC shall be final and binding on both the parties in respect of all matters of dispute arising out of this tender
- 2.25 **AGREEMENT:** The successful bidder shall have to execute an agreement in a non judicial stamp paper worth as applicable as per Odisha Stamp Duty Act as per the prescribed forms of Govt of Odisha with the Engineer-In-Charge of HHEP, Burla within 15 days of issue of order or before supply and execution of the work for the contract failing which the order will be liable for cancellation

Signature
16.04.26
C&P Head, HHEP, Burla
5107



ODISHA HYDRO POWER CORPORATION LTD.,

O/o Sr. GENERAL MANAGER, HIRAKUD HYDRO ELECTRIC PROJECT,
POST BOX. NO. 5, BURLA – 768017, DISTRICT: SAMBALPUR (ODISHA), INDIA
PHONE: 0663-2950721(O), 2950765(R), E-Mail: srgmhps_burla@yahoo.co.in
GST NO. 21AAACO2575P1Z9, CIN : U40101OR1995SGC003963

SECTION III SPECIAL TERMS AND CONDITIONS

- 3.1 **TERMS OF PAYMENT:** 100% payment shall be made after successful completion of work and verification thereof by the Engineer-in-charge subject to submission of bill in triplicate, Original Manufacturers O&M Manual, as built drawing and warrantee certificate in original. Payment shall be released through NEFT/ RTGS on submission of cancelled blank cheque by the supplier/ contractor. TDS as applicable shall be deducted.
- 3.2 **CONSIGNEE:** Divisional Head, Generation Division, HHEP, Burla
- 3.3 **PAYING OFFICER:** Fin. Wing Head, HHEP, Burla
- 3.4 **ENGINEER-IN-CHARGE:** Divisional Head, P&C Division, HHEP, Burla
- 3.5 **LIQUIDATED DAMAGE :** If the supplier fails to complete the work within the schedule completion period or any extension granted thereto, OHPC shall recover from the Supplier a sum of half percent (0.5 percent) of the order value for each calendar week of delay or part thereof, subject to maximum 05% of the order value towards liquidated damages.
- 3.6 **FORCE MAJEURE:** The firm shall not be liable for any penalty for delay or for failure to perform the contract for reasons of force majeure such as acts of God, public agitation, natural calamities etc. In such an event, the firm shall immediately intimate the undersigned about the occurrence of delay and after receipt of the same, OHPC may / may not accept the same by way of extension of contract period, as may be justified.
- 3.7 **REJECTION OF MATERIALS:** If the materials supplied by the supplier are found defective during transit or otherwise not in conformity with the requirements, OHPC shall either reject the materials or request the supplier in writing to replace the same. The supplier on receipt of such intimation shall replace the defective materials free of cost to OHPC, if the supplier fails to do so, OHPC may:
- i) At his option replace such defective materials and recover the extra costs so involved from the supplier, **AND /OR**
 - ii) Terminate the contract with forfeiture of Composite Bank Guarantee
- 3.8 **EXTENSION OF TIME:** If the completion of work delayed due to reasons beyond the control of the successful bidder, the firm before the schedule date of completion, shall give notice to OHPC in writing of his claim for an extension of time. OHPC on receipt of such notice may agree to extend the contract period as may be reasonable but without prejudice to other terms and conditions of the contract
- 3.9 **COMPLETENESS OF WORK:** The successful Supply, retrofitting, testing and commissioning as per the order and specification duly certified by the Engineer-in-charge will be treated as completeness of work. Any equipment or fitting which are not mentioned in the specification

but which are useful and necessary shall be deemed to have been included and shall be supplied by the supplier without any financial liability to OHPC.

- 3.10 **AFTER SALE SERVICE:** The supplier shall provide After Sale Service as and when required by the customer.
- 3.11 **SITE VISIT::** Bidders are advised to visit the site of HHEP, Burla to study the philosophy of existing breaker and required dimensions before submitting their offer for retrofitting of ACB.
- 3.12 **PRE-DISPATCH INSPECTION & TESTING:** Inspection and Tests shall be performed to ensure ACB compliance with these technical specifications. Responsibility for conducting the inspections and tests shall rest with the supplier. The Purchaser's representative shall participate in the ACB inspections and shall witness the testing as per the relevant IS/IEC at the suppliers / manufacturers premises. The Bidder shall give at least 15days advance notice prior to the commencement of testing so that purchaser's representative can plan to witness the tests. Copies of test reports duly approved by the Purchaser shall be submitted by the Supplier.
- 3.13 **DESPATCH INSTRUCTION:** After approval of Inspection & Test reports, the dispatch instruction shall be issued. After issue of dispatch instruction the materials should be securely packed and dispatched duly insured directly to the destination i.e. Main Store, Burla Power House, HHEP, Burla at the supplier's risk by Road Transport only.
- 3.14 **O&M MANUAL, DOCUMENTS AND DRAWINGS:** O&M Manual: The Supplier shall submit Operation and Maintenance Manual in **triplicate** for all the ACB components and complete switchgear. The Manual shall include ACB Operating instructions & applicable drawings. The detail drawings include Complete assembly drawings of the ACB showing plan, elevation typical sectional views, plan showing location of channels, welding of channels to floor embedded parts etc, General Arrangement drawing, complete wiring diagrams , Schematic Control diagrams as applicable
- 3.15 **INDEMNITY BOND:** The contractor should be liable to fully indemnify to the Dept. for payment of compensation under Workman Compensation Act. VII of 1923 on account of the workman employed by the firm and full amount of compensation paid will be recovered from the firm. In this regard, the firm have to furnish the Indemnity Bond in non-judicial stamp paper worth Rs.100/- before execution of the work.
- 3.16 **INSURANCE:** The work place is situated in the vicinity of extra high voltage and risk profile zone. Risk profile varies from ordinary accidents to even substance of fatal injury. The firm is entirely responsible for insuring the personnel and equipments working / deployed at the site for carrying out the job inside Burla Power House against all risk of sustaining minor injury to fatal accidents and / or against any damage occurred to the personnel and machinery of other organization including OHPC due to activities of firm within Burla Power House premises while performing the contractual obligation. Any damage or loss to OHPC property will have to be repaired / replaced by the firm at no extra cost to OHPC

3.17 **SAFETY:** Before and during carrying out the work, it shall be the entire responsibility of the firm to take all the safety precautions, as required. The firm shall make all the arrangements for the safety of their labourers directly or indirectly employed in the work. OHPC shall not be responsible in any way for any injury/disablement, accident to any worker on this account and will be free from any legal binding in this regard. OHPC will not be responsible to pay any compensation to the worker of the firm or any outside firm.

3.18 **TEST CERTIFICATE:** Type Test results as per relevant IS of the product, shall be submitted along with the Technical Bid.

3.19 **RELEVANT STANDARDS:**

IEC/IS 60947-2 General Switchgears

IEC-60947-1/IEC-60068-2-6/7-Shock and vibration protection

IEC 60529 – Degrees of Protection provided by Enclosures (IP Code)

3.20 **FIRM'S RESPONSIBILITY**

- i) The supply, retrofitting, testing and successful commissioning of Air Circuit Breaker at respective switchgear panels of HHEP is the responsibility of the successful bidder.. Hence supply of any additional materials / equipments related to the works, which have not been specifically mentioned but are required and necessary for the completeness of the job will also be carried out by the firm as per the instruction of Engineer-in-Charge and the same shall be the responsibility of the successful bidder without any extra financial liability to OHPC. Hence, the bidder has to quote accordingly in the price bid. All the scaffolding, tools and tackle required for execution of works are to be arranged by the firm and will be kept in their custody
- ii) Gate pass for men & materials for entry into the power house is to be arranged by firm from competent authority of Odisha Industrial Security Force, Burla . The responsibility of OHPC is limited to recommend for issue of gate pass
- iii) All the damaged and dismantled parts after replacement shall be handed over to the Engineer-in-Charge or his authorized representative
- iv) The firm themselves or any of their authorized and responsible representative should be present at work site continuously during the entire period of execution to receive instruction from the OHPC supervising Officers. Any instruction given to firm's representative shall be deemed to have been given to the firm. Any damage or loss to the equipment to be replaced or any other surrounding equipment or infrastructure during execution of work will be to the firm's account and will have to be replaced / repaired as the case may be, by the firm

3.21 **TENDERER'S DEFAULT LIABILITY:** OHPC may write notice of default to the tenderer and may terminate the contract in circumstances as mentioned below.

- i) If the supplier fails to complete the work within the time specified
- ii) If the supplier fails to comply with any of the provisions of this contract
- iii) If any additional cost will be paid by OHPC for the complete supply, the supplier will be liable for payment of such cost and penalty for delay

3.22 **FACILITIES TO BE PROVIDED BY THE OHPC**

- i) Power supply free of cost at work site
- ii) **Shutdown:** Arrangement of shutdown of units / feeders / equipment on advance written request by the agency
- iii) As per availability, one room in the Erectors' Hostel may be provided for accommodation of Executives of the firm on chargeable basis
- iv) Recommendation for obtaining gate pass

3.23 **DEVIATION FROM SPECIFICATION:** The tenderers may deviate from the specification while quoting their offers, if, in their opinion such deviation is in line with requirement and also compatible to the existing system. However all such deviations, should be clearly indicated in the Annexure-7 giving full justification for such deviation and OHPC is empowered either to consider or reject those deviations, as per facts and prudential norms practiced.

Shree
16.04.20
C&P Head, HHEP, Burla
15/04

SECTION – IV
SCOPE AND TECHNICAL SPECIFICATION

4.1 **SCOPE OF THE CONTRACT:** The scope of the contract shall be 1) Inspection & testing at Manufacturers Works before dispatch, packing and delivery F.O.R destination along with all fittings and accessories, retrofit , testing and commissioning of following Air Circuit Breakers at respective Switchgear Panels of Burla Power House.

- a) **Supply and retrofit of existing Merlin Gerin make ACB with new compatible ACB**
02 no of 4pole 800 Amp ACB with Microprocessor based electrically Draw out type 4Pole, 800Amp Air Circuit Breaker with overload, short circuit & earth fault protection, with dismantling, modification, assembling & wiring for Incomer-II of UAB-I & II Panels of HHEP, Burla
- b) Supply and retrofit of existing **Merlin Gerin make ACB with new compatible ACB**
02 no of 4pole 1250 Amp ACB with Microprocessor based electrically Draw out type 4Pole, 1250 Amp Air Circuit Breaker with overload, short circuit & earth fault protection, with dismantling, modification, assembling & wiring for SSB-I incomer-I & II Panels of HHEP, Burla.

4.2 **SCOPE OF WORK :**

- i) Successful Contractor has to Supply & retrofit the required ACB in place of the existing Merlin Gerin Make Air Circuit Breaker. Specification of existing Air Circuit Breakers to be replaced are given below.

Specification of existing 4 pole 800Amp ACB used at Incomer-II of UAB-1 & II of BPH is as follows:

- a) **Merlin Gerin Masterpact - M08HI** , ACB with overload, short circuit , earth fault protection, Rated insulation voltage U_i -1000V, 50/60Hz ,Breaking capacity -100KA , Rated Operational Voltage -480/690V ,Short time withstand -75KA , 1Sec , Spring Charging & Closing Control Voltage- **220V AC** Tripping Control Voltage -220 V DC (Coil one) & 220V AC (Coil two).

Specification of existing 4 pole 1250 Amp ACB used at SSB- 1 & 2 is as follows:

- a.) **Merlin Gerin Masterpact -M12HI** , ACB with overload, short circuit , earth fault protection, Rated insulation voltage U_i -1000V, 50/60Hz ,Breaking capacity -100KA , Rated Operational Voltage -480/690V ,Short time withstand -75KA , 1Sec , Spring Charging , Closing & Tripping Control Voltage- 220V DC .
- ii) Shifting of ACBs from Store to Switchgear panel where retrofiting is required to be carried.
- iii) The Scope covers disconnections of internal wiring of existing Merlin Gerin / Schneider make ACB in the existing switchgear panels & re-wiring of new breaker after retrofiting . In doing so supplier has to remove the existing breaker along with its cradles and primary / secondary disconnection / drawout contacts etc. Further while retrofiting the cradle of new breaker and breaker compartment cover need to be suitably modified and installed in the existing switchgear compartment.

- iv) Primary and Secondary disconnections need to be modified, if required to suit for power and control circuit of new breaker inside the existing switchgear cell.
- v) Any special tools and tackles required for erection, commissioning & maintenance are to be arranged by the supplier.
- vi) Conducting IR Value measurement, commissioning tests of breaker and checking / testing of circuit breaker operation with protective relays and furnishing of site acceptance test reports to HHEP after completion of work
- vii) **The Air Circuit Breaker to be supplied under this contract shall confirm to relevant IS/IEC**
- viii) It is not intent to specify completely here in all details of design & construction of the equipment. However, the equipment shall confirm in all respects to high standards of engineering, design & workmanship & be capable of performing in continuous operation safely in a manner acceptable to the purchaser. The Purchaser shall be entitled to reject any work or material which in his judgment is not in full accordance herewith.
- ix) **Site Visit** : Details of work involved in the retrofitting work have been included here to the extent possible. **However , it is advised that bidder's representative visits the site of HHEP, Burla to study the philosophy of existing breaker and required dimensions before submitting their offer for retrofitting of ACB.**
- x) **The bidder shall furnish the Guaranteed Technical Particulars of the offered ACB as per the prescribed format as in Annexure-9**

15/04
16.04.20
C&P Head, HHEP, Burla

SECTION-V

Annexure - 1

BANK GUARANTEE
(Security for performance)

Ref.....

Bank Guarantee No.....

Date.....

To

The Unit Head,
Hirakud Hydro Electric Project,
Odisha Hydro Power Corporation Ltd.,
Burla, Sambalpur, Odisha-768017
FAX: 0663-2430712
E-mail: srgmhps_burla@yahoo.co.in

IN CONSIDERATION OF HIRAKUD HYDRO ELECTRIC PROJECT, BURLA a generating unit of M/s ODISHA HYDRO POWER CORPORATION LIMITED, a Government of Odisha PSU company registered under the Companies Act,1956, having its registered office at **Odisha State Police Housing & Welfare Corporation Building, VaniVihar Chowk, Janpath, Bhubaneswar-751022** (herein after called the "**Corporation**" which expression shall include its successors in business and assigns) having placed an order on _____ a partnership firm / Sole Proprietor / a company registered under the Companies Act,1956, having its office at _____ herein after called "**firm / agency**" (Which expression shall include its successors in business and assigns) vide PO / WO No. _____ dated _____ for (specify nature of job) _____ (hereinafter called "the Order" which expression shall include any amendments/alterations thereto the order issued by the Corporation") for " _____ " for the Corporation and the corporation having agreed:

- i) Not to insist upon immediate payment of security deposit for Rs. _____ (Rupees _____) only (being the value of the order as specified in the said order) for execution of work for the fulfillment and performance of the said order.
 - ii) That **the firm / agency** shall furnish a security for the performance of the **firm's / agency's** obligations and/or discharge the liability in connection with the said order and the corporation having agreed with the **firm / agency** to accept a Bank Guarantee for the security deposit for Rs. _____ (Rs. _____).
1. We, _____ Bank having office at _____ (hereinafter referred to as "the Bank" which expression shall includes its successors and assigns) at the request and on behalf of "**the firm / agency** " hereby agree to pay to "the Corporation" without any demur on first demand an amount not exceeding Rs. _____ (Rupees _____) only against any loss or damage, costs, charges and expenses caused to or suffered by "the Corporation" by reason of non performance and fulfillment or for any breach on the part of "**the contract**" of any of the terms and conditions of the said "Order".
 2. We, _____ Bank, further agree that "the Corporation" shall be the sole judge whether the said "**firm / agency**" has failed to perform or fulfill the said "order" and the extent of loss, damage, cost, charges and expenses suffered or incurred or would be suffered or incurred by "the Corporation" on account thereof and we waive in favour of "the Corporation" all the rights and defences to which we as guarantors and/or the **firm / agency** may be entitled to.
 3. We, _____ Bank, further agree that the amount demanded by "the Corporation" as such shall be final and binding on "the Bank" as to "the Bank's" liability to pay the amount demanded and "the Bank" undertake to pay "the Corporation" the amount so demanded on first demand without any demur notwithstanding any dispute raised by "**the firm / agency**" or any suit or other legal proceedings including arbitration pending before any court, tribunal or arbitrator relating thereto, our liability under this guarantee being absolute and unconditional.

4. We, _____ Bank, further agree with "the corporation" that "the corporation" shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said "order" /or to extend time of performance by the "**the firm / agency**" from time to time or to postpone for any time to time any of the powers exercisable by "the corporation" against "**the firm / agency**" and to forbear to enforce any of the terms and conditions to "the order" and we shall not be relieved from our liability by reason of any forbearance, act or omission on the part of " the corporation" or any indulgence by "the corporation" to "**the firm / agency**" or by any such matter or things whatsoever which under the law relating to sureties would but for this provision have the effect of relieving us.

5. However, it has been agreed between "**the firm / agency**" and "the corporation" that there shall be only one Bank Guarantee for the security deposit valid till the end of the defects liability period as per the terms of order No. _____ dated _____ .

6. We, _____ Bank, hereby lastly undertake not to revoke this guarantee during its currency except with the previous consent of "the Corporation" in writing.

7. Notwithstanding anything contained herein above:
 - i) Our liability under this guarantee shall not exceed Rs.....
 - ii) This Bank Guarantee shall be valid up to and including; and
 - iii) We the _____ Bank through our local branch office at **ODISHA** (Name & Address of the Local Branch at **ODISHA**) are liable to pay the guarantee amount or any part thereof under this Bank Guarantee only and only if you serve upon us a written claim or demand on or before dt _____ from the date of expiry of this guarantee.

8. This guarantee shall not be determined or affected by the liquidation or winding up, dissolution or change of constitution or insolvency of " **the firm / agency** " and the Bank, but shall in all respects and/or all purposes be binding and operative on "the Bank" until payment of all moneys payable by "**the firm / agency** " in terms thereof.

IN WITNESS whereof, the Bank _____, through its authorized Officer, has set its hand and stamp on this _____ day of _____ at _____.

For
 _____ Bank,
 Address

Signature _____

Name _____
 (Designation)

Power of Attorney No. _____

For
 Bank

Banker's Stamp and Full address.

Dated this _____ day of _____, 20____

TENDER SPECIFICATION NO. HHEP- 33/2026

Annexure - 2

NO RELATION CERTIFICATE

THIS IS TO CERTIFY THAT I HAVE NO RELATIONSHIP WITH ANY EMPLOYEE SERVING UNDER OHPC LTD, ODISHA. IN CASE THE ABOVE STATEMENT IS FOUND TO BE FALSE, I MAY BE DEBARRED FROM ANY PAYMENT DUE ON ACCOUNT OF THIS CONTRACT.

SIGNATURE OF THE TENDERER

Place:

TENDER SPECIFICATION NO. HHEP- 33/2026
EXPERIENCE CERTIFICATE

PAST HISTORY OF EXECUTION OF SIMILAR TYPE OF WORKS/ ORDERS.
(To be filled by the Bidder)

Sl.No.	Name of the Customer with Address	Order No. / Dt. with certified copies	Month/Year of Supply.

Signature of the Tenderer
With seal

TENDER SPECIFICATION NO. HHEP- 33 /2026

(Check list)

Annexure – 4

(This Proforma should be filled in with all information and should be furnished with tender)

1.	Cost of Tender paper	Yes/No
2.	Copy of manufacturer's registration certificate in case of manufacturers / Authorised dealership certificate in case of authorized dealers	Yes/ No
3.	Bid Security declaration as per prescribed format furnished:	Yes/No
4.	Copies of PAN, GSTIN Registration	Yes/No
5.	Proof of eligibility	Yes/No
6	Type test reports as per relevant IS of offered ACB submitted	Yes/ No
7	Whether agreed to submit Operation and Maintenance Manual in triplicate, drawing and documentation of offer breaker if placed order as per tender clause	Yes/ No
8.	Whether the bidders representative has visited the site of HHEP,Burla and physically accessed the dimension detail for retrofitting of new ACB .	Yes/No
9	Validity of Offer is 120 days from the date of opening of tender:	
7.	Nature of Price quoted: "FIRM":	Yes/No
8.	Agreeable to terms of payment as mentioned in tender specification:	Yes/No
	Agreement– Whether agreeable to execute agreement in OHPC prescribed form	
9.	Whether agreeable to furnish security deposit/	Yes/No
10.	Guarantee / Warranty as per specification:	Yes/No
11.	Price bid in closed separate envelope	Yes/No
12.	Whether agreed to all the terms and conditions of the specification:	Yes/No
13.	Whether copy of earlier order/supply to reputed customers attached:	Yes/No
14	Original/Copy of Money receipt in support of Purchase of Tender	Yes/No
15	Copy of the tender document signed on each page	Yes/No
16.	An affidavit by the tenderer that the firm is not blacklisted.(As per prescribed format as in Annexure-5)	Yes/No

SIGNATURE OF TENDERER:

NAME:

DESIGNATION (SEAL) :

TENDER SPECIFICATION NO. HHEP- 33/2026

AFFIDAVIT

(To be sworn before the Notary)

I/We, (Name of the bidder) a Company incorporated under the provisions of the Indian Companies Act / Proprietorship/ Firm registered under Indian Partnership Act./Sole Proprietor having its Registered office/ Corporate Office / at _____ and represented through Sh _____ duly authorized person (Designation) hereby solemnly declare & affirm as under:-

1. That we, _____ (Name of the bidder) have not been blacklisted / debarred / disqualified by any Govt. or any of its agencies or PSUs etc. last three years upto the date of submission of the bid.

DEPONENT

Place:

Date:

VERIFICATION

I/We, _____ (Name of the bidder), the above named deponent, do hereby verify that the contents of Paragraph -1 of this affidavit is true to my personal knowledge and nothing has been concealed and no part of it is false.

Verified at _____ this _____ day of _____.

DEPONENT

TENDER SPECIFICATION NO. HHEP- 33/2026

DECLARATION FORM

To,
The C&P Head,
Hirakud Hydro Electric Project,
Burla – 768017,
Dist – Sambalpur (Odisha).

Sir,

Having examined the above specification together with terms and conditions referred to therein, I/We the undersigned hereby agree to undertake the work if allotted to us in all respects as per the specification and general conditions, at the rates offered by us. Our offer is valid upto 120days from the date of tender opening.

1. I/ We hereby undertake to have the materials delivered and work to be executed in complete shape within the time specified in this tender.
2. I/ We hereby guarantee the technical particulars given in the tender will be executed skillfully for which, I / We guarantee for successful operation for a period of _____ months.
3. I/ We hereby declare that, the tender specification submitted does not contain any addition / alteration / deletion / correction if any shape or manner.
4. I/ We hereby certify that the amount have been deposited towards the cost of the specification by remitting Cash/Bank Draft No. _____.
5. In the event of order being decided in my/our favour, I/We agree to furnish the Security deposit-cum-Performance Bank Guarantee in the manner acceptable to O.H.P.C. for a sum as applicable, within 15 (Fifteen) days of issue of Letter of Intent / detail work order / Purchase order and before signing of contract agreement, failing which I/We clearly understand that the said Letter of Intent / the order will be liable to be withdrawn by Odisha Hydro Power Corporation Ltd., Hirakud Hydro Electric Project, Burla

Signed this day of 20

Yours faithfully,

Signature with Designation and Seal

(This form should be duly filled up by the tenderer and must be submitted along with the original copy of the offer).

TENDER SPECIFICATION NO. HHEP- 33/2026
DEVIATION FROM SPECIFICATION (TECHNICAL & COMMERCIAL)

Tenderer shall enter below particulars of his alternative proposals for deviations from the specification if any.

Sl. No.	Clause No of Tender Specification	Deviations from Specification	Justification for Deviation

PLACE :

DATE :

SIGNATURE OF TENDERER :

NAME :

DESIGNATION (SEAL) :

TENDER SPECIFICATION NO. HHEP- 33/2026, ANNEXURE-8

GUARANTEED TECHNICAL PARTICULARS

The GTP is to be filled up in this format and, to be submitted along with the Technical Bid. This is intended for speedy comparison of various bidders GTP. The bidder shall fill the particulars against appropriate items in respect of each rating and type of equipment offered in the broad categories listed below.

Sl. No.	Particulars	Unit	Bidder's Data for	
			04Pole 800 Amp ACB	04Pole 1250 Amp ACB
1	Name and Address of the Manufacturer			
2	Complete Model No. offered			
3	Type of Air Circuit Breaker			
4	Confirming Standard			
5	Air Circuit Breaker Rating	A		
6	No. of Poles	No		
7	Rated Operational Voltage Ue	V		
8	Rated Frequency	Hz		
9	Rated Insulation Voltage Ui	V		
10	Rated Impulse withstand voltage Uimp	KV		
11	Insulation level of the breaker			
a)	One minute dry withstand voltage (KVrms)	KV		
b)	One minute wet withstand voltage (KV rms)	KV		
c)	Impulse withstand test voltage (KV peak)	KV		
12	Rated Continuous Current at 40°C	A		
13	Rated Making capacity (KA peak), Icm (at voltage)	KA		
14	Rated service short circuit breaking capacity Ics	KA		
15	Rated Ultimate short circuit breaking capacity Icu	KA		
16	Rated Short time withstand current and short time delay Icw for 1 Sec.	KA		
17	Spring Charging & Closing Control Voltage	V		
18	Tripping Control Voltage	V		
19	Operations - cycle			
20	CB Operation counter Provided as standard accessory.			
21	Minimum clearance in air			
a)	Between phase (live parts) in mm	mm		
b)	Between live part and earth in mm	mm		
c)	Centre distance between phase in mm	mm		
22	No. of Auxiliary contact	No		
23	Operating Temperature	°C		
24	Storage Temperature	°C		
25	Protection functions			
i	Overload			
ii	Short circuit			
iii	Earth Fault (G)			
iv	Phase Unbalance			
v	Neutral Protection			
vi	Self protection against over temperature			

26	Operating mechanism			
a)	Store energy type with operation by means of chargeable spring with geared motor and provision for manual charging. Yes / No			
Sl. No.	Particulars	Unit	Bidder's Data for	
			04Pole 800 Amp ACB	04Pole 1250 Amp ACB
b)	Shall be with a built-in anti-pumping feature or a separate anti pumping rela. Yes / No			
27	Mechanical trip devices / Indications			
a)	Mechanical trip deice available, specify			
b)	Mechanical 'ON-OFF' indication and mechanical spring charged indication should be provided. Yes / No			
28	Connection / disconnection mechanism / Interlocks			
a)	Shall prevent sliding of CB from SERVICE to TEST position or vice versa, unless the ACB is open / OFF. YES/ NO			
b)	Shall prevent closing of ACB, unless it is in SERVICE or TEST position. YES/NO			
c)	Shall be posible to disconnect the breaker without having to open the door. YES/NO			
d)	Name plate indicating, Breaking capacities lcs & lcu as well as short time withstand rating, lcw and other details shall be as per IS. YES / NO			
29	Limits of Voltages for satisfactory operation of the following devices as %age of normal voltage			
a)	Spring Charging Motor			
b)	Shunt Trip Coil			

Signature and seal of Bidder



ODISHA HYDRO POWER CORPORATION LTD.,

O/o Sr. GENERAL MANAGER, HIRAKUD HYDRO ELECTRIC PROJECT,
POST BOX. NO. 5, BURLA – 768017, DISTRICT: SAMBALPUR (ODISHA), INDIA
PHONE: 0663-2950721(O), 2950765(R), E-Mail: srgmhps_burla@yahoo.co.in
GST NO. 21AAACO2575P1Z9, CIN : U40101OR1995SGC003963

PART-B PRICE BID

TENDER CALL NOTICE NO. HHEP- 33 /2026

Name of work : **Supply and Retrofit of 02 Nos of 800Amp ACB and 02 Nos of 1250Apm ACB for replacement against Merlin Gerin make ACB of SSB-I, incomer-I & II and Incomer-II of UAB-I & II of Burla Power House**

Allex
16.04.26
C&P Head, HHEP, Burla

15/04

TENDER SPECIFICATION NO. HHEP- 33 /2026
PRICE BID

Name of work : Supply and Retrofit of Microprocessor based electrically draw out type air circuit breakers 02 nos of capacity 800A each and 02 Nos of capacity 1250A each ACBs with overload, short circuit & earth fault protection with dismantling , modification, assembling and wiring for existing Incomer-II of UAB-I & II Panel and SSB-I incomer-I and Incomer-II panel respectively of Burla Power House

SI No	Description	Plz Specify the Make & Model No	HSN Code	Unit	Qty	Basic Price/Unit including all charges excluding GST (Rupees in Words)	Basic Price/Unit including all charges excluding GST (Rupees in Figure)	Unit GST		Unit Price with taxes and duties in Rs	Total amount in Rs
								I (%)	J (Rs)		
A	B	C	D	E	F	G	H	I (%)	J (Rs)	K	L=K*F
1	Supply & Retrofit , testing and commissioning along with Dismantling, Modification, Assembling, and wiring of existing 4pole 800Amp ACB with Microprocessor based electrically Draw out type Electrical 4Pole 800Amp Air Circuit Breaker with overload, short circuit, earth fault protection. Breaking Current -100KA Frequency -50HZ Short time withstand capacity -75KA, 1sec Spring & closing control voltage – 220V AC Tripping control voltage – 220V DC & 220 V AC (Two Coils)			Set	2						

SI No	Description	Piz Specify the Make & Model No	HSN Code	Unit	Qty	Basic Price/Unit including all charges excluding GST (Rupees in Words)	Basic Price/Unit including all charges excluding GST (Rupees in Figure)	I (%)	Unit GST	Unit Price with taxes and duties in Rs	Total amount in Rs
A	B	C	D	E	F	G	H		K	L=K*F	
2	Supply & Retrofit, testing and commissioning along with Dismantling, Modification, Assembling, and wiring of existing 4pole 1250Amp ACB with Microprocessor based electrically Draw out type Electrical 4Pole 1250Amp Air Circuit Breaker with overload, short circuit, earth fault protection. Breaking capacity -100KA Frequency -50HZ Short time withstand capacity -75KA, 1sec Spring , closing & tripping control voltage – 220V DC			Set	2						
3	Total Offered amount in Rs (SI No-1+2)										
4	(Rupees.....)										

Note: Interested bidders are requested to visit the site of HHEP, Burla and access the philosophy of existing breakers proposed for replacement and required dimensions detail before submitting their offer for the above work

PLACE :

SIGNATURE OF TENDERER :

DATE :

NAME :

DESIGNATION (SEAL) :