



OFFICE OF THE SR. GENERAL MANAGER (ELECTRICAL)
UPPER INDRAVATI HYDRO ELECTRIC PROJECT, MUKHIGUDA,
DIST: KALAHANDI-766026, ODISHA, E-mail: sgmel_uihep@ohpcltd.com

ODISHA HYDRO POWER CORPORATION LTD. (A GOVERNMENT OF ODISHA UNDERTAKING)
Regd. Office OSPH & W.C Building, Vanivihar Chhak, Janpath, Bhoinagar, Bhubaneswar-751022,
Tel: 91-0674-2542983, 2542802, 2545526, 2542826, Fax:2542102, E-Mail: ohpc.co@gmail.com / md@ohpcltd.com
WEB: www.ohpcltd.com, CIN: U40101OR1995SGC003963

TENDER SPECIFICATION NO. UIHEP-04/2026-27 DATED 13.04.2026
TENDER PAPER FOR SUPPLY, ERECTION, TESTING & COMMISSIONING OF
EXHAUST FANS OF UIHEP, MUKHIGUDA.

Name of the Firm / Manufacturers: -

.....
.....

Corresponding Address with Contact Telephone No.

.....
.....
.....
.....
.....

Cost of the Tender Paper: Rs. 6,000/- + GST 18%
= Rs. 7,080/-



OFFICE OF THE SR. GENERAL MANAGER (ELECTRICAL)
UPPER INDRAVATI HYDRO ELECTRIC PROJECT, MUKHIGUDA,
DIST: KALAHANDI-766026, E-mail: sgmel_uihep@ohpcltd.com

ODISHA HYDRO POWER CORPORATION LTD. (A GOVERNMENT OF ODISHA UNDERTAKING)

Regd. Office OSPH & W.C Building, Vanivihar Chhak, Janpath, Bhoinagar, Bhubaneswar-751022,
Tel: 91-0674-2542983, 2542802, 2545526, 2542826, Fax:2542102, E-Mail: ohpc.co@gmail.com / md@ohpcltd.com

WEB: www.ohpcltd.com, CIN: U40101OR1995SGC003963

CONTENTS

PART – 1:

TECHNO – COMMERCIAL BID

1.	Section – I: Instruction to Tenderer	Page – 5
2.	Section – II: General Terms & Conditions	Page – 6 to 9
3.	Section – III: Special Terms & Conditions	Page – 10 to 11
4.	Section – IV: Scope & Technical Specification	Page – 12 to 13
5.	Section – V: Annexures	Page – 14 to 20

PART – II:

PRICE BID

1.	Price Bid	Page –22 to 23
----	-----------	----------------



OFFICE OF THE SR. GENERAL MANAGER (ELECTRICAL)
UPPER INDRAVATI HYDRO ELECTRIC PROJECT, MUKHIGUDA,
DIST: KALAHANDI-766026, ODISHA, E-mail: sgmel_uihep@ohpcltd.com

ODISHA HYDRO POWER CORPORATION LTD. (A GOVERNMENT OF ODISHA UNDERTAKING)
Regd. Office OSPH & W.C Building, Vanivihar Chhak, Janpath, Bhoinagar, Bhubaneswar-751022,
Tel: 91-0674-2542983, 2542802, 2545526, 2542826, Fax:2542102, E-Mail: ohpc.co@gmail.com / md@ohpcltd.com
WEB: www.ohpcltd.com, CIN: U40101OR1995SGC003963

(TECHNO – COMMERCIAL BID)

**“TENDER PAPER FOR SUPPLY, ERECTION, TESTING & COMMISSIONING OF
EXHAUST FANS OF UIHEP, MUKHIGUDA”**

TENDER CALL NOTICE NO: UIHEP-04/2026-27 DATED 13.04.2026



OFFICE OF THE SR. GENERAL MANAGER (ELECTRICAL)
UPPER INDRAVATI HYDRO ELECTRIC PROJECT, MUKHIGUDA,
DIST: KALAHANDI-766026, ODISHA, E-mail: sgmel_uihep@ohpcltd.com

ODISHA HYDRO POWER CORPORATION LTD. (A GOVERNMENT OF ODISHA UNDERTAKING)
Regd. Office OSPH & W.C Building, Vanivihar Chhak, Janpath, Bhoinagar, Bhubaneswar-751022,
Tel: 91-0674-2542983, 2542802, 2545526, 2542826, Fax:2542102, E-Mail: ohpc.co@gmail.com / md@ohpcltd.com
WEB: www.ohpcltd.com, CIN: U40101OR1995SGC003963

NOTICE INVITING TENDER No. UIHEP-04/2026-27 DATE 13.04.2026

Sealed Tenders are invited in two part i.e. (i) Techno Commercial bid & (ii) Price bid in separate sealed envelopes from reputed original equipment manufacturers / channel partners / reputed firm / service provider having similar works experience for the work as mentioned below.

Description of work	Cost of tender paper (Non-refundable) in Rs.	EMD in shape of DD/Banker's Cheque only (Refundable) in Rs.	Period of sale / download of tender document	Last date & time of receipt of tender	Date & time of opening of Techno commercial Bid
Supply, Erection, Testing & Commissioning of Exhaust fans of UIHEP, Mukhiguda.	7,080/- (inclusive of GST)	29,014/-	From 21.04.2026 to 04.05.2026 up to 11.00 Hrs	04.05.2026 (up to 11:30 Hrs)	04.05.2026 at 12:30 Hrs

For details of the tender documents, terms and conditions please visit our website www.ohpcltd.com

-Sd-
C&P Head
UIHEP, Mukhiguda



OFFICE OF THE SR. GENERAL MANAGER (ELECTRICAL)

UPPER INDRAVATI HYDRO ELECTRIC PROJECT, MUKHIGUDA,

DIST: KALAHANDI-766026, ODISHA, E-mail: sgmel_uihep@ohpcltd.com

ODISHA HYDRO POWER CORPORATION LTD. (A GOVERNMENT OF ODISHA UNDERTAKING)

Regd. Office OSPH & W.C Building, Vanivihar Chhak, Janpath, Bhoinagar, Bhubaneswar-751022,

Tel: 91-0674-2542983, 2542802, 2545526, 2542826, Fax:2542102, E-Mail: ohpc.co@gmail.com / md@ohpcltd.com

WEB: www.ohpcltd.com, CIN: U40101OR1995SGC003963

SECTION – I

INSTRUCTION TO TENDERER

1.1 SCOPE & TECHNICAL WORK:

The scope & technical work is as per Section IV.

1.2 CORRESPONDENCE:

All correspondences shall be made in English only to the C&P Head, Office of the Unit Head, UIHEP, Mukhiguda, Dist. Kalahandi, Pin: 766026.

1.3 SCHEDULE OF DATES:

The various crucial dates relating to “**Supply, Erection, Testing & Commissioning of Exhaust fans of UIHEP, Mukhiguda**” are as notified in the tender notice.

1.4 COST OF TENDER PAPER:

The tender specification should be accompanied with the cost of tender paper as notified in the tender notice in shape of Bank draft / Bankers Cheque from any Nationalized Bank / Scheduled bank drawn in favour of “Odisha Hydro Power Corporation Ltd.” payable at IOB, Mukhiguda / SBI, Jaipatna along with the tender documents for the tenderers those who download the tender specification from OHPC website or original money receipt of OHPC for the tenderers those who purchase the tender specification from the OHPC Corporate Office, Bhubaneswar / concerned OHPC units.

1.5 EARNEST MONEY DEPOSIT:

The tenderers are required to deposit EMD of an amount as notified in the tender notice (refundable) in the shape of Bank draft / Bankers Cheque from any Nationalized Bank/ Scheduled Bank drawn in favour of “Odisha Hydro Power Corporation Ltd.” payable at IOB, Mukhiguda / SBI, ADB Branch, Jaipatna along with the tender documents, failing which the tender shall be out rightly rejected. The EMD amount will not carry any interest. The EMD of unsuccessful bidders shall be returned after finalization of tender. The EMD of successful tenderers shall be returned / refunded after submission of performance security deposit.

1.6 ELIGIBILITY CRITERIA: The firm should be a reputed original equipment manufacturers / authorised dealer / channel partners / reputed firm / service provider having similar works experience. Documentary evidence in support of eligibility criteria shall be submitted.

1.7 SITE VISIT: The prospective firms are advised to depute their technical experts at their cost to visit the site in well advance (much before the last date of receipt of tender) to assess and examine the site conditions, requirements, the nature and quantum of work so as to prepare a realistic and competitive price for participation in the tender.



OFFICE OF THE SR. GENERAL MANAGER (ELECTRICAL)
UPPER INDRAVATI HYDRO ELECTRIC PROJECT, MUKHIGUDA,
DIST: KALAHANDI-766026, E-mail: sgmel_uihep@ohpcltd.com

ODISHA HYDRO POWER CORPORATION LTD. (A GOVERNMENT OF ODISHA UNDERTAKING)

Regd. Office OSPH & W.C Building, Vanivihar Chhak, Janpath, Bhoinagar, Bhubaneswar-751022,
Tel: 91-0674-2542983, 2542802, 2545526, 2542826, Fax:2542102, E-Mail: ohpc.co@gmail.com / md@ohpcltd.com

WEB: www.ohpcltd.com, CIN: U40101OR1995SGC003963

SECTION – II GENERAL TERMS AND CONDITIONS

2.1 SUBMISSION OF BID

2.1.i) **The following Documents to be submitted along with Techno-Commercial Bid in part-I in one sealed envelope super scribed as Techno Commercial Bid.**

- Tender Paper Cost
- EMD
- Self-attested copies of IT PAN and GSTIN.
- Proof of eligibility criteria as per clause No. 1.6 regarding experience.
- Download copy of the tender document / Tender paper to be signed on each page.
- Any other documents as per the check list given in Annexure – 4.
- An affidavit by the tenderer, that the firm is not black listed. (as per prescribed format in Annexure – 5)
- A declaration by the tender, that the tenderer has no relation with any employee serving under OHPC as per Annexure – 2.

2.1.ii. Price bid in the prescribed form given in Part – II in another sealed envelope super scribed as “Price Bid”. Both the sealed envelope should be placed inside another sealed envelope super scribed with TCN no. & marked as “**SUPPLY, ERECTION, TESTING & COMMISSIONING OF EXHAUST FANS OF UIHEP, MUKHIGUDA**” & to be sent to (or dropped in the box kept in) the office of the tender inviting authority.

2.2 CLARIFICATION & AMENDMENT

- I) At any time before submission of bid, the client may, for any reason, modify the tender documents by amendment. The amendment, if any, shall be issued through an addendum which shall be kept on the official website of OHPC for information of the firms / agencies who intend to submit quotation. Before submitting the bid the firms / agencies are advised to go through the website to find out such addendum / errata / corrigendum if any issued by the client. The addendum / errata / corrigendum will be binding on all the firms / agencies submitting the quotation. The client also reserves the right without any obligation or liability to accept or reject any or all the quotation at any stage of the process, to cancel or modify the process or any part thereof or to vary terms and conditions at any time without assigning any reason thereof.
- II) Tenderers shall carefully examine the tender documents and the technical specification. Should a tender find any discrepancies or omissions from the specification or other documents, he should at once intimate the authority and obtain clarification in writing. This, however, does not entitle the tenderer to ask time beyond the due date fixed for receipt of tenderers.
- III) In case any bidder who has submitted the bid before issue of corrigendum / addendum etc., if desired can submit a bid super scribing as “Revised bid against TCN” on the envelope containing the tender documents.

2.3 CORRIGENDUM: Modification of specifications and extension of closing date or opening date of Tender, if required, will be made by corrigendum. Copies of such corrigendum will be floated in OHPC website only. This shall be signed and shall form a part of the Tender. Tenderers are required to visit the website for such corrigendum / errata / addendum if any.

2.4 SUBMISSION OF BIDS: The tender has been invited under tow part bidding system i.e. Techno commercial Bid and Price Bid. The interested agencies are advised to submit two separate

sealed envelopes for each bid i.e. Techno commercial and Price bid super scribing “Techno Commercial Bid of Tender for **“Supply, Erection, Testing & Commissioning of Exhaust fans of UIHEP, Mukhiguda”** on the Techno commercial Bid and super scribing “Price Bid of Tender for **“Supply, Erection, Testing & Commissioning of Exhaust fans of UIHEP, Mukhiguda”** on the price bid. Both sealed envelopes should be kept in a third sealed envelope super scribing **“TCN NO.- UIHEP-46/2025-26 dated 04.02.2026 “Supply, Erection, Testing & Commissioning of Exhaust fans of UIHEP, Mukhiguda”**”.

Bidders shall quote their price as per the price bid format only given in PART – II.

2.5 OPENING OF TECHNO COMMERCIAL BID AND PRICE BID: The Techno Commercial Bid shall be opened on the scheduled date and time as per tender notice in the Office of the Unit Head or tender inviting authority in presence of the tenderer or authorized representative of the tenderer if any who wish to be present on that spot at that time.

The price bid of only those tenderers will be opened whose techno commercial bids are found in order. The date and time of opening of the price bids of technically qualified firms will be intimated later and separately. **If the date of receipt / opening of tender happens to be or declared as a holiday, the next working day will be treated as the corresponding effective date.**

2.6 EVALUATION:

- i) Evaluation shall be based on techno-commercial and price bids submitted by the bidders.
- ii) Bidders fulfilling the eligibility criteria as per the above evaluation shall be called for opening of the price bids.
- iii) Bidders not meeting the eligibility criteria shall not be considered for further evaluation.
- iv) The competent authority reserves the right to cancel any or all bids without assigning any reason thereof.

2.7 OUTRIGHT REJECTION CRITERIA:

- i) Bidders whose bid is not received in time.
- ii) Bidders submitting false evidences that cannot be verified during the process shall be disqualified / the contract to be terminated on detection.
- iii) The Bidder blacklisted by any Central Government / State Government / PSU / Government Bodies.
- iv) Bidder not submitting the bid in line with the Tender requirement.
- v) Conditional bids shall not be considered and will be out rightly rejected in very first instance.
- vi) Tender paper cost / EMD

2.8 PRICE: The quoted price shall be FIRM & FOR UIHEP, Mukhiguda. The price shall include cost of materials, packing and forwarding, freight & insurance along with Installation, Testing & Commissioning Charges for Exhaust fans. The tenderers shall have to furnish the GST Rate and Amount with HSN Code in their offer clearly as mentioned in Price Bid Format. No price variation in any shape will be allowed. OHPC will not be held responsible for rise in the cost of labour / raw material / transportation and any such circumstances. The tenderers are advised to quote single price for the item as mentioned in the Price Bid format both in figures and in words. The materials are to be supplied in full and good conditions to the consignee.

- i) The tenderers are advised to quote in the prescribed Price Bid format only. No other mode will be entertained. However, if there is any deviation in the specification and quantity of the quoted item, the bidder should clearly mention in the Annexure – 6 (Deviation for technical or Commercial specification) of the Technical bid with justification. However, decision of OHPC will be final and binding for its consideration / rejection.
- ii) The tenderer are requested to quote separately the detail of taxes applicable with % on Basic Price and Rates in Rupees.

2.9 TAXES & DUTIES:

- i) Only GST shall be paid as per rule.
- ii) Taxes deductible at source shall be deducted from the bills of the firms as per prevailing Acts & rules.

2.10 BILLS: The bills in triplicate along with following documents shall be submitted to the consignee / EIC for processing for payment.

- a) Warranty Certificate.
- b) Operation and Maintenance manual of Exhaust Fan along with technical details of supplied materials.

2.11 VALIDITY: The bids should have a validity period of 120 days from the date of opening of tenders, failing which the tenders will be rejected.

2.12 COMPLETION PERIOD:

- i. **Delivery of Materials for Exhaust Fans:** The material shall be delivered in all respect within **60 days** of issue of the order. All the materials alongwith spares and accessories should be securely packed and dispatched directly to the consignee's store by Road Transport only with due transit insurance. Materials alongwith packing list, Warrantee certificate and operation / maintenance manual, drawing and literature of the bought-out items if any in triplicate are to be dispatched alongwith the consignment. After receipt of all the materials at consignee store, the same shall be jointly verified by the firm and the Engineer-in-Charge. The date of receipt of total ordered materials in good conditions at consignee store and physical verification thereof duly certified by the consignee will be treated as date of delivery.
- ii. **Installation, testing and commissioning of Exhaust Fans:** Installation, testing and commissioning of new exhaust fans shall be completed within **150 days** from the date of intimation by Engineer-in-Charge. Installation, testing and commissioning will be done by the firm as per direction of Engineer-in-Charge. The date of successful installation and commissioning duly certified by the Engineer-in-Charge will be treated as the date of completion of the work.

2.13 PERFORMANCE SECURITY DEPOSIT:

The successful tenderer has to deposit 10% of the ordered value towards performance security deposit within 15 (fifteen) days of placement of order by OHPC in shape of Bank draft / Banker Cheque drawn in favour of "Odisha Hydro Power Corporation Ltd." payable at IOB, Mukhiguda / SBI, ADB Jaipatna or in shape of BG (Bank Guarantee) pledged in favour of OHPC, UIHEP, Mukhiguda as per the prescribed format at Annexure – 1. In case of non-fulfilment of the contract conditions, the security deposit will be forfeited without assigning any reason thereof. No interest shall be paid on the security deposit. The security Deposit will be released after completion of guarantee period on receipt of clearance from EIC for the work.

2.14 INSURANCE: Transit insurance of materials should be done by the supplier / contractor at their cost with their own insurance company. The responsibility of delivery of the materials at destination in good condition rests with the supplier / contractor. Any claim with the insurance company or transport agency arising due to loss or damage in transit has to be settled by the supplier / contractor. The tenderer shall undertake for replacement of materials immediately, on receipt of such information from Consignee / Engineer-In-Charge regarding damage or loss, without waiting for settlement for their claims with the carriers and underwriters.

2.15 OHPC AUTHORITY RESERVES THE RIGHTS:

- a) To reject any or to accept any or all tenders.
- b) To increase or decrease the quantity of materials or to change the distribution schedule covered under the tender without assigning any reason thereof.

c) The Work order will be liable for cancellation in the event of un-satisfactory supply / delay in completion of the work and non-observance of relevant clauses of the Work order.

2.16 WARRANTY: The materials covered by the specification should be guaranteed for satisfactory performance and against defect in design, materials and workmanship for a period of one year from the date of commissioning of Exhaust Fans. Any defects noticed during this period, shall be replaced / rectified free of cost. The firm shall have to furnish a Warranty certificate to this effect to the Consignee.

2.17 COMPENSATION: The firm / bidder shall be fully responsible for paying compensation, if any under the Labour Act. On account of workmen deployed by him. He must have followed all the safety rules, procedures and provide all the required protective equipments to his workmen as they are to work in surroundings of Extra High Voltage system. OHPC L in no way will be responsible for payment of any compensation. The bidder / firm is fully responsible for any loss or damage of OHPC L property caused during the course of execution of the work and the cost of such damage shall be borne by the Contractor / Bidder.

2.18 FORCE MAJEURE: The supplier / contractor shall not be liable for any liquidated damage for delay or for failure to perform the contract for reasons of force majeure such as act of God, act of public enemy, acts of Government, fires, flood, epidemics, quarantine restriction, strikes, freight embargoes provided that the supplier has brought to the notice to the costumer in writing of the cause of delay in advance. The costumer shall verify the facts and grant such extensions as the facts justify.

2.19 EXTENSION OF DELIVERY / COMPLETION PERIOD: If the work is delayed due to reason beyond the control of the contractor, the contractor shall without delay give notice to OHPC in writing of his claim for any extension of time within 14 days of such occurrence. OHPC on receipt of such intimation may agree to extend the delivery / completion period as may be reasonable but with prejudice to other terms & condition of the contract.

2.20 JURISDICTION: All disputes shall be under the jurisdiction of the court nearest to the place where the authority of OHPC, who has executed the agreement.

2.21 AWARD OF WORK: The work will be awarded on the basis of L-1 rate.

2.22 SETTLEMENT OF DISPUTE:

- i) **Amicable Settlement:** Any dispute(s) or difference(s) arising out of or in connection with the contract shall to the extent possible, be settled amicably between the parties.
- ii) **Dispute Resolution:** Decision of competent authority of OHPC shall be final and binding on both the parties in respect of all matters of dispute arising out of this tender.

2.23 ACCEPTANCE OF ORDER: The successful bidder shall confirm by returning a duplicate copy of the work order to this office duly signed on each page within from the date of issue of work order as a token of acceptance.



OFFICE OF THE SR. GENERAL MANAGER (ELECTRICAL)
UPPER INDRAVATI HYDRO ELECTRIC PROJECT, MUKHIGUDA,
DIST: KALAHANDI-766026, E-mail: sgmel_uihep@ohpcltd.com

ODISHA HYDRO POWER CORPORATION LTD. (A GOVERNMENT OF ODISHA UNDERTAKING)

Regd. Office OSPH & W.C Building, Vanivihar Chhak, Janpath, Bhoinagar, Bhubaneswar-751022,
Tel: 91-0674-2542983, 2542802, 2545526, 2542826, Fax:2542102, E-Mail: ohpc.co@gmail.com / md@ohpcltd.com
WEB: www.ohpcltd.com, CIN: U40101OR1995SGC003963

SECTION – III **SPECIAL TERMS AND CONDITIONS**

- 3.1 TERMS OF PAYMENT:** Payment shall be released in a phased manner as follows
- i) **50% payment** of supply value with GST shall be released within 30 days of receipt of 100% material in full & good condition at consignee's store and verification thereof by the EIC subject to furnishing of security deposit @ 10% of the work order value and fulfilling all other terms and conditions.
 - ii) Balance 50% of supply value with GST & 100% of work contract (erection, testing & commissioning) value with GST shall be released after successful completion of work on submission of work completion certificate duly certified by the EIC, Warrantee certificate in triplicate, Proof of security deposit / copy of bank guarantee towards performance security.
 - iii) Payment shall be released through Cheque / NEFT / RTGS on submission of cancelled blank cheque by the supplier / contractor. Bill for the supply is to be submitted to the consignee & bill for the installation work is to be submitted to the EIC.
 - iv) TDS as applicable shall be deducted from the bill.
- 3.2 ENGINEER-IN-CHARGE:**
Divisional Head, Maintenance Division, UIHEP, Mukhiguda
- 3.3 PAYING OFFICER:**
FINANCE WING HEAD, UIHEP, Mukhiguda.
- 3.4 CONSIGNEE:**
Divisional Head, Operation Division, UIHEP, Mukhiguda.
- 3.5 LIQUIDATED DAMAGE FOR DELAY IN COMPLETION OF CONTRACT:** If the supplier / contractor fails to complete the work within the scheduled completion period specified in the contract or any extension granted there to, the purchaser shall recover from the supplier / contractor, liquidated damage @ 0.5% of the relevant contract price (ex-work price) separately for supply & works for each calendar week of delay or part thereof of delay. For this purpose, the date of completion of work certified by the EIC shall be reckoned as date of completion of contract. The total amount of liquidated damage shall not exceed 5% (five percent) of the total contract value (ex-work price). The imposition of liquidated damage is however subject to force majeure condition.
- 3.6 FORCE MAJEURE:** The firm shall not be liable for any penalty for delay or for failure to perform the contract for reasons of force majeure such as acts of God, public agitation, natural calamities etc. In such an event, the firm shall immediately intimate the undersigned about the occurrence of delay and after receipt of the same, OHPC may / may not accept the same by way of extension of contract period, as may be justified.
- 3.7 REJECTION OF MATERIALS:** If the materials supplied by the supplier are found defective during transit or otherwise not in conformity with the requirements, OHPC shall either reject the materials or request the supplier in writing to replace the same. The supplier on receipt of such intimation shall replace the defective materials free of cost to OHPC, if the supplier fails to do so, OHPC may:
- i) At his option replace such defective materials and recover the extra costs so involved from the supplier, AND / OR
 - ii) Terminate the contract with forfeiture of Composite Bank Guarantee.

- 3.8 COMPLETENESS OF WORK:** The successful completion of work as per the order and specification duly certified by the Engineer-in-Charge will be treated as completeness of work. Any equipment or fitting which are not mentioned in the specification but which are useful and necessary for completion of work shall be deemed to have been included and shall be supplied by the supplier without any financial liability to OHPC.
- 3.9 INSURANCE:** The work place is situated in the vicinity of extra high voltage and risk profile zone. Risk profile varies from ordinary accidents to even substance of fatal injury. The firm is entirely responsible for insuring the personnel and equipments working / deployed at the site for carrying out the job inside Indravati Power House / Valve House against all risk of sustaining minor injury to fatal accidents and / or against any damage occurred to the personnel and machinery of other organization including OHPC due to activities of firm within Indravati Power House premises / Valve House while performing the contractual obligation. Any damage or loss to OHPC property will have to be repaired / replaced by the firm at no extra cost to OHPC.
- 3.10 SAFETY:** Before and during carrying out the work, it shall be the entire responsibility of the firm to take all the safety precautions, as required. The firm shall make all the arrangements for the safety of their labourers directly or indirectly employed in the work. OHPC shall not be responsible in any way for any injury / disablement, accident to any worker on this account and will be free from any legal binding in this regard. OHPC will not be responsible to pay any compensation to the worker of the firm or any outside firm.
- 3.11 TENDERER'S DEFAULT LIABILITY:** OHPC may write notice of default to the tenderer and may terminate the contract in circumstances as mentioned below.
- a) If the supplier fails to complete the work within the time specified.
 - b) If the supplier fails to comply with any of the provisions of this contract.
 - c) If any additional cost will be paid by OHPC for the completion of work, the supplier will be liable for payment of such cost and penalty for delay.
- 3.12 FACILITIES TO BE PROVIDED BY THE OHPC:**
- i) Power supply free of cost at work site.
 - ii) Recommendation for obtaining gate pass.
- 3.13 DEVIATION FROM SPECIFICATION:** The tenderers may deviate from the specification while quoting their offers, if, in their opinion such deviation is in line with requirement and also compatible to the existing system. However, all such deviations, should be clearly indicated in the Annexure – 6 giving full justification for such deviation and OHPC is empowered either to consider or reject those deviations, as per facts and prudential norms practiced.



OFFICE OF THE SR. GENERAL MANAGER (ELECTRICAL)
UPPER INDRAVATI HYDRO ELECTRIC PROJECT, MUKHIGUDA,
DIST: KALAHANDI-766026, E-mail: sgmel_uihep@ohpcltd.com

.....
ODISHA HYDRO POWER CORPORATION LTD. (A GOVERNMENT OF ODISHA UNDERTAKING)

Regd. Office OSPH & W.C Building, Vanivihar Chhak, Janpath, Bhoinagar, Bhubaneswar-751022,
Tel: 91-0674-2542983, 2542802, 2545526, 2542826, Fax:2542102, E-Mail: ohpc.co@gmail.com / md@ohpcltd.com

WEB: www.ohpcltd.com, CIN: U40101OR1995SGC003963

SECTION – IV
SCOPE & TECHNICAL SPECIFICATION

4.1 SCOPE OF THE CONTRACT: The scope covers “**Supply, Erection, Testing & Commissioning of Exhaust fans of UIHEP, Mukhiguda**”.

4.2 SCOPE OF WORK: The work is to be carried out on Turnkey basis.

- i) Supply of all materials under part – A for successful completion of work confirming to the specification and standards of TAC/relevant IS.
- ii) Erection, Testing and Commissioning of materials under part – A of new Exhaust Fans. All consumables required for carrying out the work are to be provided by the contractor.

4.3 CLIMATIC AND SERVICE CONDITIONS: The Climatic conditions at site under which the Equipment shall operate satisfactorily are as follows:

- a) Maximum ambient Temperature – 50°C
- b) Maximum daily average ambient Temperature – 45°C
- c) Maximum yearly weighted ambient Air Temperature – 32°C
- d) Maximum relative humidity – 100 %
- e) Maximum Annual Rain fall – 2860 mm
- f) Minimum Annual Rain Fall – 1527 mm
- g) No. of months during which Tropical Monsoon conditions prevails – 5 and ½ Months.

4.4 FITTINGS AND ACCESSORIES: All fittings and accessories which may not be specifically mentioned in the specifications but are usual and necessary for equipment shall be deemed to be included in the contract and shall be supplied by the supplier / contractor without any extra cost to the customer.

4.5 TESTS: The supplier / contractor shall conduct in its factory / workshop all tests as required under the relevant ISS/IES/CBIP report with latest amendments or in its absence he may have the tests conducted at any standard testing laboratory approved by the purchaser. The cost incidental to the testing during manufacture, assembly and final testing after completion of equipment shall be borne by the supplier / contractor. If the purchaser has reason to doubt the adequacy of the suppliers / contractor testing facilities, these may be conducted at any test house approved by the purchaser at the cost of the supplier / contractor.

4.6 TECHNICAL SPECIFICATION: **Supply, Erection, Testing & Commissioning of Exhaust fans of UIHEP, Mukhiguda** is as given bellow –

Sl. No.	Description	Qty
Part – A		
1	Heavy duty Industrial Axial type exhaust fans of size 300mm complete with driving motors, inlet guards, louvers for exhaust opening, fixing devices and all other devices necessary for successful operation. Rate of air flow – 1145 CMH Blade Material – Cast Iron Product Type – Wall Mounted Make – CG, Havells or any other reputed make	16 Nos.

2	Heavy duty Industrial Axial type exhaust fans of size 450mm complete with driving motors, inlet guards, louvers for exhaust opening, fixing devices and all other devices necessary for successful operation. Rate of air flow – 2850 CMH Blade Material – Cast Iron Product Type – Wall Mounted Make – CG, Havells or any other reputed make	02 Nos.
3	Heavy duty Industrial Propeller type exhaust fans of size 600mm complete with driving motors, inlet guards, louvers for exhaust opening, fixing devices and all other devices necessary for successful operation. Rate of air flow – 9400 CMH Blade Material – Cast Iron Product Type – Wall Mounted Make – CG, Havells or any other reputed make	15 Nos.
4	Heavy duty Industrial Propeller type exhaust fans of size 450mm complete with driving motors, inlet guards, louvers for exhaust opening, fixing devices and all other devices necessary for successful operation. Rate of air flow – 2850 CMH Blade Material – Cast Iron Product Type – Wall Mounted Make – CG, Havells or any other reputed make	04 Nos.
5	Heavy duty Industrial Propeller type exhaust fans of size 300mm complete with driving motors, inlet guards, louvers for exhaust opening, fixing devices and all other devices necessary for successful operation. Rate of air flow – 1710 CMH Blade Material – Cast Iron Product Type – Wall Mounted Make – CG, Havells or any other reputed make	09 Nos.
Part – B		
2	Erection, testing & commissioning of the above fans which are to be retrofitted in our existing position (at the top of the wall).	46 Nos.

The quantity shown above is tentative only. Authority reserves the right to increase or decrease the quantity.

SECTION – V

Annexure – I

BANK GUARANTEE (Security for Performance)

In consideration of the Odisha Hydro Power Corporation Limited, a Company incorporated under the laws of India and having its registered office at Bhubaneswar, Odisha – 751001, India (hereinafter called OHPC) having agreed to exempt M/s (Hereinafter called the “Contractor”) from the demand, under the terms and conditions of an agreement No. dated made between and for (Hereinafter called the “agreement”), of security deposit for satisfactory performances of materials and works (as detailed in the agreement) during the guarantee period (as detailed in the agreement) and for the fulfilment by the Contractor(s) of the terms and conditions contained in the said agreement, on production of bank Guarantee for Rs. (Rupees only) against any loss or damage caused to or suffered or would be caused to or suffered by OHPC by reason of any breach by the said Contractor(s) of any terms and conditions contained in the said agreement.

We, Bank Limited (hereinafter referred to as “the Bank”) at the request of the said Contractor do hereby undertake to pay to OHPC an amount not exceeding against any loss or damage caused to or suffered or would be caused to or suffered by OHPC by reason for any breach by the said contractor of any of the terms and conditions contained in the said contract.

1. We, Bank Limited do hereby undertake to pay the amounts due and payable under this guarantee without any demur, merely on demand from OHPC stating that the amount claimed is due by way of loss or damage caused to or would be caused to or suffered by OHPC by reason of breach by the said contractor of any of the terms and conditions contained in the said contract or by reason of the said Contractors failure to perform the said contract. Any such demand made on the bank shall be conclusive as regards the amount due and payable by the Bank under this guarantee. However, our liability under this guarantee shall be restricted to an amount not exceeding Rs.
2. We, the Bank Limited to pay OHPC any money so demanded notwithstanding any dispute or disputes raised by the said Contractor in any suit or proceeding pending before any Court or Tribunal relating thereto, our liability under this present being absolute and unequivocal.

The payment so made by us under this bond shall be a valid discharge of our liability for payment there under and the Contractor(s)/Supplier(s) shall have no claim against us for making such payment.

3. We, the Bank Limited further agree that the guarantee herein contained shall remain in full force and effect during the period that would be taken for the performance of the said contract and that it shall continue to be so enforceable till all the dues of the OHPC under or by virtue of the said agreement, have been fully paid and its claims satisfied or discharged until Manager (El.), Odisha Hydro Power Corporation certified that the terms and conditions of the said agreement have been fully and properly carried out by the said contractors and accordingly, discharges this guarantee. Unless a demand or claim under this guarantee is made on us in writing on or before the expiry of months from the last delivery of materials or months from its use whichever is earlier we shall be discharged from all liability under this guarantee thereafter.

4. We, the Bank Limited further agree with OHPC that OHPC shall have the fullest liberty, without our consent and without affecting in any manner our obligations hereunder, to vary any of the terms and conditions of the said agreement to extend time of performance by the said Contractor(s) and to forbear or enforce any of the terms and conditions relating to the said agreement and we shall not be relieved from our liability by reason of any such variation, postponement, or extension being granted to the said Contractor(s) or by any such matter of thing whatsoever which under the law relating to sureties would but for this provision have effect of so relieving us.
5. This guarantee shall not be discharged due to the change in the name, style and constitution of the Bank or the Contractors(s) / supplier(s).
6. We, the Bank Limited lastly undertake not to revoke this guarantee during its currency except with the previous consent of OHPC in writing.

Dated the day of **2026** -

Witness with Address

1.

2.

For Bank Limited.

NO RELATION CERTIFICATE

THIS IS TO CERTIFY THAT I HAVE NO RELATIONSHIP WITH ANY EMPLOYEE SERVING UNDER OHPC LTD., ODISHA. IN CASE THE ABOVE STATEMENT IS FOUND TO BE FALSE, I MAY BE DEBARRED FROM ANY PAYMENT DUE ON ACCOUNT OF THIS CONTRACT.

SIGNATURE OF THE TENDERER

Place

EXPERIENCE CERTIFICATE

PAST HISTORY OF EXECUTION OF SIMILAR TYPE OF WORKS / ORDERS

(To be filled by the Bidder)

Sl. No.	Name of the Customer with Address	Order No. / Dt. With certified copies	Month / Year of Supply	Value of order

**Signature of the Tenderer
With seal**

CHECKLIST

(This Proforma should be filled in with all information and should be furnished with tender)

1	Cost of Tender Paper	Yes / No
2	Copy of manufacturer's registration certificate in case of manufacturers / Authorized Dealership / Channel partner certificate as the case may be	Yes / No
3	Earnest Money / undertaking furnished:	Yes / No
4	Copies of PAN, GSTIN Registration	Yes / No
5	Proof of eligibility (Past Experience, Experience Certificate / Work Order / Purchase Order / Agreement Copies)	Yes / No
6	Agreed to Tender Validity as per Tender Specification	Yes / No
7	Nature of Price quoted: "FIRM"	Yes / No
8	Agreeable to terms of payment as mentioned in tender specification: Agreement – Whether agreeable to execute agreement in OHPC prescribed from	Yes / No
9	Whether agreeable to furnish security deposit /	Yes / No
10	Guarantee / Warranty as per specification:	Yes / No
11	Price bid in closed separate envelope	Yes / No
12	Whether agreed to all the terms and conditions of the specification:	Yes / No
13	Copy of the tender document signed on each page	Yes / No
14	An affidavit by the tender that the firm is not blacklisted	Yes / No
15	Make / Brand / Description of materials to be supplied along with leaflet / brochure in case of supply of materials.	Yes / No
16	'No Relation' – declaration	Yes / No
17	Submitted all the annexures duly filled in.	Yes / No

**SIGNATURE OF THE TENDERER
NAME:
DESIGNATION (SEAL):**

AFFIDAVIT

(To be sworn before the Notary)

I/We, _____ (Name of the bidder) a Company incorporated under the provisions of the Indian Companies Act / Proprietorship / Firm registered under Indian Partnership act. / Sole Proprietor having its Registered office / Corporate Office / at _____ and represented through Sh _____ duly authorized person (_____ Designation) hereby solemnly declare & affirm as under: -

1. That we, _____ (Name of the bidder) have not been blacklisted / debarred / disqualified by any Govt. or any of its agencies or PSUs etc. last three years up to the date of submission of the bid.

DEPONENT

Place:

Date:

VERIFICATION

I/We, _____ (Name of the bidder), the above named deponent, do hereby verify that the contents of Paragraph – 1 of this affidavit is true to by personal knowledge and nothing has been concealed and no part of it is false.

Verified at _____ this _____ day of _____

DEPONENT

Deviation from specification (Technical & Commercial)

Tenderer shall enter below particulars of his alternative proposals for deviations from the specification if any.

Sl. No.	Clause No of Tender Specification	Deviations from Specification	Justification for Deviation

Place:
Date:

SIGNATURE OF TENDERER
NAME:
DESIGNATION (SEAL):

PART – II PRICE BID

PART – II (PRICE BID)

TENDER CALL NOTICE NO. UIHEP-04/2026-27 Dated 13.04.2026

Sl. No.	Specification	Make	Unit	Qty	Basic Rate / unit in Rs.	GST			Rate per Unit including GST in ₹ 9=(5+8)	Total Amount including GST in ₹ 10=(9x4)
						HSN Code	%age	In Rs.		
1	2		3	4	5	6	7	8		
A	Supply of materials									
1	Heavy duty Industrial Axial type exhaust fans of size 300mm complete with driving motors, inlet guards, louvers for exhaust opening, fixing devices and all other devices necessary for successful operation. Rate of air flow – 1145 CMH Blade Material – Cast Iron Product Type – Wall Mounted Make – CG, Havells or any other reputed make		Nos.	16						
2	Heavy duty Industrial Axial type exhaust fans of size 450mm complete with driving motors, inlet guards, louvers for exhaust opening, fixing devices and all other devices necessary for successful operation. Rate of air flow – 2850 CMH Blade Material – Cast Iron Product Type – Wall Mounted Make – CG, Havells or any other reputed make		Nos.	02						
3	Heavy duty Industrial Propeller type exhaust fans of size 600mm complete with driving motors, inlet guards, louvers for exhaust opening, fixing devices and all other devices necessary for successful operation. Rate of air flow – 9400 CMH Blade Material – Cast Iron Product Type – Wall Mounted Make – CG, Havells or any other reputed make		Nos.	15						

4	Heavy duty Industrial Propeller type exhaust fans of size 450mm complete with driving motors, inlet guards, louvers for exhaust opening, fixing devices and all other devices necessary for successful operation. Rate of air flow – 2850 CMH Blade Material – Cast Iron Product Type – Wall Mounted Make – CG, Havells or any other reputed make		Nos.	04						
5	Heavy duty Industrial Propeller type exhaust fans of size 300mm complete with driving motors, inlet guards, louvers for exhaust opening, fixing devices and all other devices necessary for successful operation. Rate of air flow – 1710 CMH Blade Material – Cast Iron Product Type – Wall Mounted Make – CG, Havells or any other reputed make		Nos.	09						
	Total (Part – A)									
B	Erection, testing & commissioning of the above fans which are to be retrofitted in our existing position (at the top of the wall).		Nos.	46						
	Total (Part – B)									
	Grand Total (Part – A + Part – B)									

(Rupees only)

SIGNATURE OF THE TENDERER
NAME:
DESIGNATION (SEAL)